


| | | |
|---|---|--|
|  | Public Notification of Bypass, Overflow and Spill Events | Issued: 2021-08-21 Rev.: 0 Pages: 1 of 1 |
| Angus Wastewater Treatment Plant | | |

Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 7826-BRPRAW issued September 11, 2020 for the Angus Wastewater Treatment Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

Details

| | |
|--|---|
| Location: | <i>Angus WPCP, 147 Centre Street, Angus</i> |
| Type of Event: | <input type="checkbox"/> Overflow <input checked="" type="checkbox"/> Bypass <input type="checkbox"/> Spill |
| Start Date & Time: | <i>Feb 17, 2025 at 1130 hours</i> |
| End Date & Time: | <i>Feb 17, 2025 at 2345 hours</i> |
| Total Discharge Volume (m³): | <i>1010 cubic meters</i> |
| Cause of the Event: | <i>Tertiary filters clogged, causing filters to be bypassed.</i> |

If there are any questions or concerns, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.